

## **PERC TESTS**

At the regular meeting of the Granby Board of Health on June 2, 1975, the Board adopted the following regulations regarding percolation tests and maximum ground water elevation determinations as referenced in the "State Sanitary Code", Article XI. Effective January 1, 1976.

1. Percolation tests and maximum ground water elevation determinations, to be submitted on Disposal Works Construction Permit applications, shall be conducted between March 1, and April 30, inclusive. No tests or determinations shall be made in frozen ground.
2. Disposal Works Construction Permit shall not be issued where the ground water elevation is less than four (4) feet below the bottom of the disposal area.

Effective July 1 thru December 31, 1975.

1. Disposal Works Construction Permits shall not be issued where the ground water elevation is less than eight (8) feet below the bottom of the disposal area.

### **GRANBY BOARD OF HEALTH**

Francis E. Dewitt, Chairman  
Joseph V. Choquette  
Richard G. Bombardier