

The Board of Health of the Town of Granby, acting under the authority of the General Laws and amendments and additions thereto, and by any other power thereto enabling, and acting thereunder and in accordance therewith, have, in the interest of and for the preservation of the public health, duly made and adopted the following rule and regulation April 1, 1985.

ALL NEW WELLS BEING DUG IN GRANBY MUST PRODUCE
5 gallons per minute per dwelling unit, continuously drawing water for an eight hour period for multidwellings.

Percolation tests done in 1985 cannot be extended another two years without a water table test.

GRANBY BOARD OF HEALTH

Richard G. Bombardier
Joseph V. Choquette
Charles H. White